



# valveIT<sup>®</sup>

Via Caduti di Reggio Emilia 27, 40033  
Casalecchio di Reno (BO)  
[www.valveit.com](http://www.valveit.com)  
[info@valveit.com](mailto:info@valveit.com)



# SAUDI ARABIA

APPROVAL COLLECTION

2016-2023



PRO AT FLUID CONTROL



<b>CONSULTANT: BEEAH.P.A.E</b>	<b>THE OWNER: BAHA UNIVERSITY</b>	<b>CONTRACTOR: AL FADEL CO.</b>
 مؤسسة بيهاء Beeah	 BAHIA UNIVERSITY	 <b>AL-FADEL CO.</b> For Trading & Contracting CR. ١٠٢٠١١٢٢ شركة الفاضل لتجارة والتعاقد ب.ع. ١٠٢٠١١٢٢

**PROJECT NO: 348**      **LOCATION : BAHA UNIVERSITY - BAHA(K.S.A)**  
**PROJECT NAME : MEDICAL COLLEGE**

**SUBMITTAL ( اعتماد مواد )**

New Submittal      Submittal No: BUM-M-ME-0059      Submittal Date: 15/06/2020  
 Resubmittal      Previous Submittal No:      Previous Submittal Date:

**PURPOSE OF SUBMITTAL:**

For Information       For comments       For Approval  
 ARCHITECTURAL     STRUCTURAL     HVAC     MECH     ELECTRICAL     OTHERS

**TYPE OF SUBMITTAL :**




SHOP DRAWING       AS BUILT       MATERIAL

**ATTACHED :**

CATALOG     COMPANY PROFIL     DRAWING     SAMPLE

S No.	DESCRIPTION	BRAND	SUPPLIER	REV NO.	COUNTRY OF REGION
1	المحابس والوصلات المرنة لشبكة التغذية و شبكة المياه المثلجة (Chiller) (AHU&			0	
2		Valveit	مؤسسة حلم المستقبل	0	Italy
3				0	

Contractor's Remarks:



<p style="text-align: center;"><b>CONTRACTOR ENGINEER</b></p> <p>NAME : <b>CONFIDENTIAL</b></p> <p>Signature : </p>	<p style="text-align: center;"><b>CONTRACTOR PROJECT MANAGER</b></p> <p>NAME : <b>CONFIDENTIAL</b></p> <p>Signature: </p> <p style="text-align: center;">           شركة الفاضل للتجارة والتعاقد          ب.ع. ١٠٢٠١١٢٢       </p>
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Refer to Engineer

مراجعة على الشركات وإعداد الرأى لفتح طبقات الحماى


Consultant Comments:


تم مراجعة الكتل و...  
 1- Austria - Herz  
 2- Italy - Valveit  
 3- Italy - VIC

<p><b>CONSULTANT ENGINEER</b></p> <p>NAME : Engr..Aiaa Aizyat</p> <p>Signature : </p> <p>Date: </p>	<p><b>Approval Status:</b></p> <p> <input type="checkbox"/> A Approved      <input type="checkbox"/> C Approved As Noted  <input checked="" type="checkbox"/> B Approved as Noted Resubmittal is not Required      <input type="checkbox"/> D Disapproved  <input type="checkbox"/> Resubmittal is Required       </p>
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**CONSULTANT PROJECT MANAGER**

NAME : **CONFIDENTIAL**

Signature: 

Date: 

C.C. 17/17





المشروع: مشروع إنشاء كلية الطب - جامعة الباحة  
الموضوع: بشأن اعتماد الصانع والمورد للمحابس والوصلات المرنة لشبكات تغذية المياه

المحترمين

السادة / شركة البيئة مخططون معماريون ومهندسون

السلام عليكم ورحمة الله وبركاته ... وبعد

إشارة إلى خطابكم رقم ٤١٨/ج وتاريخ ٢٤/١٠/١٤٤١هـ الموافق ١٦/٠٦/٢٠٢٠م بشأن اعتماد الصانع والمورد للمحابس والوصلات المرنة لشبكات تغذية المياه. عليه نفيد سعادتكم بأنه لا مانع لدينا من اعتماد الشركات حسب الجدول الموضح أدناه:

م	الصانع	المورد	الأفضلية	ملاحظات
١			--	
٢	فالفيت (VALVEIT)	مؤسسة حلم المستقبل	أفضلية ثانية	
٣				

على أن يتم التأكيد على المقاول بالآتي:-

- ١- ضرورة الالتزام بالملاحظات الواردة بنماذج التقديم.
- ٢- تقديم شهادات المنشأ الموثقة من الجهات الرسمية.
- ٣- الالتزام بالموصفات الفنية وجداول الكميات والمخططات المعتمدة والخاصة بالمشروع.
- ٤- تقديم عينات للاعتماد قبل البدء في التوريد.

ولكم أطيب تحياتي ...

المشرف العام على

CONFIDENTIAL

الإدارة العامة للمشروع

د. راجي بن عدنان بناني



جامعة الباحة  
رقم المعاملة: ٤١٢٢٩٧٣٦  
تاريخ التحرير: ١٤٤١/١١/١٩  
وقت التحرير: ٩:٣٨  
المرفقات:



\* 1 4 4 1 - 4 1 - 4 1 2 2 9 7 3 6 \*

الرقم : ..... التاريخ : ..... المشفوعات : .....

تليفون : ٠٠٩٦٦ - ١٧ - ٧٢٧٤١١١ فاكس : ٠٠٩٦٦ - ١٧ - ٧٢٤٧٢٧٢ ص . ب (١٩٨٨)

Tel. : 00966 17 7274111 Fax : 00966 17 7247272 AL- Baha P.O.Box (1988)







<b>CLIENT</b>  Ministry of Health Riyadh 11178 Tel: (01) 403 2259 Fax: (01) 403 2259 Riyadh - Saudi Arabia	<b>PROJECT MANAGEMENT CONSULTANT</b>  <b>Hill International</b>	<b>SUPERVISION CONSULTANT</b>  Saudi Consolidated Engineering Co. Khatib & Alami P.O. Box 3928 - Riyadh 11481 Tel: 4778384 - Fax 4779793	<b>CONTRACTOR</b> Al Fouzan Trading & General Construction Co. Box 6300 - Riyadh 11482 Tel: 4769998 Fax Ext: 160
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------

<b>PROJECT No.</b>	<b>LOCATION :</b>
<b>PROJECT NAME :</b> JEDDAH HOSPITAL -400 BED	RIYADH SAUDI ARABIA
<b>DOCUMENT TRANSMITTAL / SUBMITTAL</b>	
Ref. No. :	المستندات المقدمة
Date : 20-Jul-17	Submittal No. : JDHP-MS-ME-237
DISCIPLINE:	Re-Submittal
<input type="checkbox"/> CIVIL <input type="checkbox"/> ARCHITECTURAL <input type="checkbox"/> STRUCTURAL <input type="checkbox"/> HVAC <input checked="" type="checkbox"/> PLUMBING	<input type="checkbox"/> ELEC. & INSTRUM. <input type="checkbox"/> MEDICAL EQUIP.

ENCLOSURES (مرفقات)								
DRAWINGS	مخططات	<input type="checkbox"/>	SAMPLE	عينة	<input type="checkbox"/>	TEST DATA	<input type="checkbox"/>	بيان اختبار
MATERIAL SUBMITTAL	مواد	<input checked="" type="checkbox"/>	SKETCH	سكتش	<input type="checkbox"/>	SCHEDULES	<input type="checkbox"/>	جداول
CATALOGS	كتالوج	<input checked="" type="checkbox"/>				REPORT	<input checked="" type="checkbox"/>	تقارير
MFG. CERT.	شهادات	<input type="checkbox"/>				CLARIFICATIONS	<input type="checkbox"/>	توضيحات
SPECIFICATIONS	مواصفات	<input type="checkbox"/>				OTHERS	<input type="checkbox"/>	أخرى

رقم البند ITEM #	DRWG. NO. SPECS. NO.	رقم المخطط رقم المواصفة	رقم المراجعة REV.	بيان DESCRIPTION	عدد النسخ NO. OF COPIES	رمز القرار ACT. CODE
1			0	<b>TECHNICAL SUBMITTAL FOR VALVES</b> FOR JEDDAH HOSPITAL SEWAGE TREATMENT PLANT (SBR - CAP. : 520 - 2 X 260 M <sup>3</sup> /DAY)	3	NB
				ATTACHED 1 SOFT COPY (CD)		

<b>SPECIFICATION &amp; BOQ</b>		<b>LOCATION / USE</b>	
		TECHNICAL PLANT	
<b>SENDER (CONTRACTOR)</b>		<b>CO-ORDINATOR (K &amp; A)</b>	
Name:	<b>CONFIDENTIAL</b>	Name:	
Signature & Date:	<i>[Signature]</i> 2017/7/2017	Signature & Date:	<i>[Signature]</i>
		<b>REVIEWED BY (K &amp; A)</b>	
		Name:	
		Signature & Date:	31/7/2017
		<b>CONFIDENTIAL</b>	

**Consultant Review & Comments (K & A)**

- We are recommended to approve Valve IT – Brand (made in Italy) for Sewage Treatment Plant.
- Selection & model is approval as shown in the attached submittal, with Pressure rating PN 16.
- Installation to be as per manufacturing recommendation and approved shop drawings.
- Certificate of origin and Guarantee to be provided as per tender requirements.
- Sample to be provided.

**Project Management Review (PMO)**

- As per K&A technical approval  
 - Subject to the final acceptance

**Hill International**  
 Signature & Date: *[Signature]*

**Approved by (MOH)**

قرار وزارة الصحة

**RECEIVED ON**  
 Technical Department

Signature & Date: *[Signature]*

**ACTION CODES:**

A) Approved (موافقة)    B) Approved as noted (موافقة بملاحظات)    C) Revised And Re-Submit (مراجعة وإعادة تقديم)    D) Rejected (مرفوض)

THESE SUBMITTED DOCUMENTS ARE IN STRICT CONFORMITY WITH THE DESIGN DRAWINGS & THE SPECIFICATIONS. MINOR DEVIATIONS ARE INDICATED IN THE SUBMITTED DOCUMENTS. ALL ASPECTS OF ASSOCIATED WORKS HAVE BEEN CONSIDERED AND COORDINATED.

الوثائق المقدمة مطابقة للمواصفات والمواصفات وتم الإشارة إلى أية اختلافات بها . مع الأخذ في الاعتبار التنسيق بين جميع التخصصات المشاركة بالأعمال .



Client:



Engineer:



شركة عبدالله سعيد السعيد  
والتجارة العامة  
A. S. ALSAYED & PARTNERS  
CONTRACTING CO. LTD

10/04/2023  
س


## TECHNICAL DOCUMENTS


<b>Project Name:</b> The Garage Startup District	<b>Project Code:</b>
<b>Location:</b> Riyadh	<b>Date:</b> April 09, 2023
	<b>Ref No:</b> KACST-OEC-ASC-MAR-MEC-035
	<b>Rev No:</b> 00

Discipline:  Architectural  Structural  Electrical  Mechanical  Authority  Others

Type:  Pre-Qualification  Method Statement  Material Submittal  Sample  Other

**Description:** Material Submittal for PRV.




<b>Enclosure:</b> Technical Data Sheet and Catalog.	Supplier / Manufacturer: Valve IT Renewal Banner For Trading (RBT)
<b>Submitted By:</b> Name: <b>CONFIDENTIAL</b> Signature:  Date: April 09, 2023	<b>Received By:</b> Name: Signature: Date:

### Below portion for Consultant Supervision use only

**Comments:**

- No objection from the above mentioned supplier Valve IT for PRV valves for water supply system
- Provide all related certificates such as updates test , origin & warranty certificates
- the diameters as per approved design drawing
- provide sample for approval with complete data sheet before supply the materials
- provide details drawing for approval of installation of the PRV valve

Status:  A- Approved  B- Approved as noted  C- Revise & Resubmit  R- Rejected

Signed by: \_\_\_\_\_ Signature:  Date: 09.04.2023

### Below portion for Client use only

**Comments:**

Signed by: \_\_\_\_\_ Signature: \_\_\_\_\_ Date: \_\_\_\_\_





## CONFIDENTIAL LETTER

DATE : 9 June 2022  
TO : **CONFIDENTIAL**  
ATTN : **CONFIDENTIAL**  
Email : **CONFIDENTIAL**  
CC : SWCC PED., SWCC-SF., Project Engineer

SUB : Shoaibah Desal Plant Technology & Expire Assests Replacement Project.  
Conditional Preliminary Approval "VALVEIT Srl-Italy" for 'Ball Valve (Manually Operated)  
Size 1" and 2" ANSI#150 ".

Y. REF. : RA-SH-Q-02-0186

DATED: 31.5.2022

With reference to the above mentioned subject, Kindly be informed that SWCC hereby grants Conditional Preliminary Approval to your proposed subcontractor "VALVEIT Srl-Italy" for manufacturing and supplying "Ball Valve (Manually Operated) Size 1" and 2" ANSI#150 ".

This Approval is on Condition:

- SWCC PQ Team will Evaluate the ability based on Factory Visit to "VALVEIT Srl-Italy"
- VALVEIT Srl will Submit an extended warranty of 5 Years from PAC or 7 Years from the Date of Delivery.

NOTE: *The main contractor will be responsible for the financial, technical and the quality of these Valves.*

Regards,

**CONFIDENTIAL**

Supplier Qualification Manager:

SWCC, Riyadh, Saudi Arabia

المرفقات : التاريخ : 09/06/2022 الرقم : 18-F22-747





**CONFIDENTIAL LETTER**

**DATE** : 14 February 2021.

**TO** : Doosan Heavy Inds & Const Co Ltd.

**ATTN** : **CONFIDENTIAL**

**Email** : **CONFIDENTIAL**

CC : SWCC PED.  
CC : SWCC-PROJECT MANAGER  
CC : CONTRACT MANAGER.

**SUB** : **SHOAIBAH-NF PROJECT for Shoaibah RO Ph-4 Desal Plant.**  
**Conditional Preliminary Approval for "ValveIT Srl-Italy" for 'Butterfly, Globe, Ball, Check, Air Release Valves & Actuators upto DN 400'.**

**Y. REF.** : DH-SR- L-0280

**DATED:** 04.02.2021

With reference to the above mentioned subject, please be informed that SWCC hereby grants Conditional Preliminary Approval to your proposed subcontractor "ValveIT Srl-Italy" to manufacture and supply of 'Butterfly, Globe, Ball, Check, Air Release Valves & Actuators upto DN 400' as required for this project.

This Approval is on condition that a 3<sup>rd</sup> Party Inspection Company will monitor the complete manufacturing process of these valves and castings for these valves.

**NOTE:** The Main Contractor will be responsible for the Financial, Technical and the Quality of these Valves.

Regards,

**Engr.** **CONFIDENTIAL**  
Manager Prequalification Department.  
SWCC, Riyadh, Saudi Arabia



## CONFIDENTIAL LETTER

DATE : 18 January 2021.

TO : **CONFIDENTIAL**

ATTN : **CONFIDENTIAL**

Email : **CONFIDENTIAL**

CC : **CONFIDENTIAL**

SUB : AL JUBAIL SWRO DESALINATION PLANT PHASE 2 PROJECT  
Preliminary Approval for "ValveIT Srl-Italy" for 'Manual And Actuated  
Diaphragm Valves, Pressure Safety Valves & Air Release Valves  
(DN15~DN150)'.

Y. REF : DH-SR-L-0580

DATED: 09.12.2020

With reference to the subject mentioned above, please be informed that SWCC hereby grants Preliminary Approval to "ValveIT Srl-Italy" a sub-subcontractor of **CONFIDENTIAL** for the manufacture and supply of 'Manual & Actuated Diaphragm Valves, Pressure Safety Valves & Air Release Valves (DN15~DN150)' as required for this project.

NOTE: The Main Contractor will be responsible for the Financial, Technical and the Quality of these Valves. 9..

Regards,

**CONFIDENTIAL**





## CONFIDENTIAL LETTER

DATE : 9 April 2023

TO : **CONFIDENTIAL**

ATTN : **CONFIDENTIAL**

Email : **CONFIDENTIAL**

CC :

SUB : REPLACEMENT OF TECHNOLOGIES AND ENDED LIFETIME ASSETS OF ALJUBAIL DESALINATION PLANT PHASE 2 PROJECT.  
Final Approval for "VALVEIT Srl-Italy" for "Butterfly Valve, Globe Valve, Control Valve, Check Valve, Ball Valve, Diaphragm Valve DN15~DN2800".

Y. REF. : 21SWCG00056-2-200-LT-000930

DATED: 2.4.2023

With reference to the above mentioned subject, Kindly be informed that SWCC hereby grants Final Approval to your proposed subcontractor "VALVEIT Srl-Italy". for manufacturing and supplying "Butterfly Valve, Globe Valve, Control Valve, Check Valve, Ball Valve, Diaphragm Valve DN15~DN2800".

NOTE: *The Main Contractor will be responsible for the Financial, Technical and the Quality of these Valves.*

Regards,

**CONFIDENTIAL**

*Suppliers Qualification Manager.*

*SWCC, Riyadh, Saudi Arabia*

Preliminary Approval was issued on 09-06-2022 Ref : 18-F22-746

18-F23-471

09-04-2023

المرفات : التاريخ : الرقم :



## CONFIDENTIAL LETTER

DATE : 14 December 2022  
TO : **CONFIDENTIAL**  
ATTN : **CONFIDENTIAL**  
Email : **CONFIDENTIAL**  
CC : SWCC PED., SWCC-SF., Project Engineer

SUB : AL MOGHAMMAS RESERVIORS Water Transmission Systems Package-C.  
Conditional Preliminary Approval for "ValveIT SRL -Italy". for "Pressure Safety Valves  
Intel DN 2" Outlet DN 1 1/2" Class 150 & Class 300".

Y. REF. : AMH-SR-L-0051

DATED: 4.12.2022

With reference to the above mentioned subject, Kindly be informed that **SWCC** hereby grants Conditional Preliminary Approval to your proposed subcontractor "**ValveIT SRL -Italy**" for manufacturing and supplying "*Pressure Safety Valves Intel DN 2" Outlet DN 1 1/2" Class 150 & Class 300*".

This Approval is on condition that SWCC PQ Team will Evaluate the ability based on Factory Visit to "**ValveIT SRL-Italy**"

**NOTE:** *The Main Contractor will be responsible for the Financial, Technical and the Quality of these Equipment's.*

Regards,

**CONFIDENTIAL**

*Suppliers Qualification Manager.*

*SWCC, Riyadh, Saudi Arabi*

18-F22-1488

14/12/2022

المرفقات : التاريخ : الرقم





## TO WHOM IT MAY CONCERN

Hereby it is informed that ValveIT SRL con S.U vales valves manufactured in Italy for butterfly valve, globe valve, plug valve, check valve, pressure release valve range DN100 – DN1400 and Non-metallic check valves / Valves of range DN15 – DN100 are used in NEOM SWCC SWRO desalination plants projects

The valves are applied for low- and high-pressure seawater, reject/brine water, permeate water, and drainage networks applications

The valves are in service since September 2019 and the performance is satisfactory. This is issued on the request ValveIT SRL con S.U vales and the long-time performance of the valves and the service support of the company are under observation.

Engr. **CONFIDENTIAL**

Chairman

**NEOM SWCC SWRO &WTS PROJECT**

Date: 04.April.2017

## TO WHOM IT MAY CONCERN

We hereby confirm that: valveIT srl based in Italy with address via Caduti di Reggio Emilia 27 – 40033 Casalecchio di Reno (Bologna) website valveit.com have successfully manufactured and supplied manual and actuated valves for our project King Fahad University of Petroleum & Minerals for student housing in Kingdom of Saudi Arabia – Dahrn region and the goods was conformed based on Metito Project no.225141200 and Metito PO 225140364.

Regards



**CONFIDENTIAL**

Sr. Project Engineer  
METITO SAUDI LIMITED





# Performance Certificate

**Date:** 04<sup>th</sup> April 2023

**To:** valveIT srl

**Subject:** Certificate of Good Execution

**Project:** 12500 m3/Day SWRO Plant for Red Sea Project

**End Client:** The Red Sea Development Company (TRSDC)

To Whom it may concern,

We hereby confirm that valveIT srl, Via Caduti di Reggio Emilia 25-27 – Casalecchio di Reno (Bologna) – 40033 – Italy, has successfully manufactured and supplied manual and actuated valves for our 12500 m3/Day SWRO Plant for Red Sea Project. The mentioned items are conformed to the project requirements and 100% functional and in use inside the plant with full satisfaction from our end-user.

Year	Project
2019	RED SEA - PO 225192944 - PO 225202135 (Manual Metallic Valves)
2019	RED SEA - PO 225192950 (Pneumatic Auto Metallic Valves)
2019	RED SEA - PO 225192951 (Pneumatic Control Valves)
2020	RED SEA - PO 225202458 (On / Off Valves)
2021	RED SEA - PO 225210798 (Manual Metallic Valves)
2021	RED SEA PO 2225210931 (Manual & Electric On/Off Valves)
2021	RED SEA PO 2225211041 (Manual Metallic Valves)

The above mentioned SWRO plant, in which valveIT's valves are currently operating, is part of The Red Sea Project included in the Saudi Vision 2030 Plan. According to this plan, the Red Sea project is defined "the world's most ambitious and exciting tourism and hospitality project: a luxury destination created around one of the world's last hidden natural treasures, it is one of the projects backed by the Public Investment Fund".

The Red Sea project will include:

- 1) Red Sea International Airport
- 2) Landscape Nursery
- 3) Waste Management Facility
- 4) Hotel Destinations
- 5) Construction Village with a Central Medical Facility
- 6) Coastal Village

METITO SAUDI LTD

Name: **CONFIDENTIAL**  
Signature: Company  
Stamp:



**METITO SAUDI LIMITED Limited Liability Company PO Box 245392 Riyadh 11312 Kingdom of Saudi Arabia**

الرياض هاتف: +٩٦٦ ١١ ٤٧٤٢٢٧٧ فاكس: +٩٦٦ ١١ ٢٣٧٩٩٤٤  
Riyadh Tel. +966 11 474 2277 Fax: +966 11 237 9944

CR. 1010288154 – Capital SR 2,000,000

س.ت: ١٠١٠٢٨٨١٥٤ رأس المال ٢.٠٠٠.٠٠٠.٠٠٠ ريال سعودي